



Centurion Fire Control™

Ontario Fire Code Requirements for Fire Protection Systems Maintenance

		Monthly	Semi-Annually	Annually	5 Year	6 Year	12 Year
Portable Fire Extinguishers (PFE)							
What	Inspect and sign tag - not obstructed, no visible damage, pressure guage in "green"			Perform annual maintenance and re-certification, re-tagging	Empty, internal exam, hydrostatic test and rebuild /recharge for water and CO2 PFEs	Empty, internal exam and rebuild/recharge for dry powder PFEs	Hydrostatic test of dry powder PFE's
Who	Designated internal employee or qualified 3rd party PFE technician			Qualified 3rd party PFE technician	Qualified 3rd party PFE technician	Qualified 3rd party PFE technician	Qualified 3rd party PFE technician
Reference	NFPA 10			NFPA 10	NFPA 10	NFPA 10	NFPA 10
Fire Alarm Systems							
What	Dayly and monthly required system performance checks.			Perform Annual system inspection and maintenance, re-certification, documentation			
Who	Designated internal employee or qualified 3rd party alarm technician			Qualified 3rd party alarm technician			
Reference	ULC S536			ULC S536, NFPA 72			
Emergency Lights							
What	30 second bulb and battery check			Annual maintenance, battery "stress" test, documentation			
Who	Designated internal employee or qualified 3rd party technician			Designated internal employee or qualified 3rd party technician			
Reference	NFPA 101			NFPA 101			
Hood Suppression Systems							
What		Semi-annual inspection and maintenance procedure, certification, documentation		(Systems used seasonally can be serviced annually)			Hydrostatic test of tank, pressure cartridges, hoses
Who		Qualified 3rd party kitchen system technician					Qualified 3rd party kitchen system technician
Reference		NFPA 17A					NFPA 17A

Seasonal: All Water and Wet Chemical Fire Extinguishers and Kitchen System tanks that are exposed to freezing temperatures should be moved to a heated location