



Centurion Fire Control™

289-878-9114
centurionfire.ca

CERTIFICATE OF INSPECTION

CUSTOMER _____
ADDRESS _____

DATE _____
CONTACT _____
TELEPHONE _____

SYSTEM DESCRIPTION

MAKE/MODEL _____	AUTOMATIC SHUT-OFFS	YES	NO	OPERATING PROPERLY
TANK SIZE/DATE _____	ALARM			
LINKS _____	GAS			
HOOD LENGTH _____	FAN			
"K" PFE _____				

	LIST OF APPLIANCES	FLOW PTS	REQ'D NOZZLE	OK?
1	_____			
2	_____			
3	_____			
4	_____			
5	_____			
6	_____			
	TOTAL FLOW PTS	0		
	TANK MAX FLOW PTS			

MAINTENANCE CHECKLIST

(CIRCLE)

TANK AND CONTROL BOX SECURELY INSTALLED AND DAMAGE FREE	YES	NO
TANK PRESSURE GAUGE IN OPERABLE RANGE	YES	NO
PRESSURIZED GAS CYLINDER PROPER WEIGHT AND DAMAGE FREE	YES	NO
SYSTEM TEST-FIRED AND AUTOMATIC SHUT-OFFS PERFORMED PROPERLY	YES	NO
REMOTE PULL STATION OPERATES PROPERLY	YES	NO
CORRECT QUANTITY AND POSITIONING OF FUSIBLE LINKS	YES	NO
REPLACED FUSIBLE LINKS	YES	NO
SUFFICIENT NOZZLES FOR TYPE OF APPLIANCES PER MANUFACTURER	YES	NO
NOZZLES REMOVED, CLEANED, FREE OF ANY GREASE BLOCKAGE, RE-INSTALLED	YES	NO
NEW BLOW-OFF CAPS INSTALLED	YES	NO
NOZZLES PROPERLY ALIGNED WITH APPLIANCES	YES	NO
FAN WARNING SIGN ON HOOD	YES	NO
DATE OF NEXT HYDROSTATIC TEST OF SYSTEM TANK _____		

COMMENTS

SYSTEM DIAGRAM



TECHNICIAN _____

SIGNATURE _____